Domaine Immobilier et Infrastructures

EPFL PL DII BS 127 (Bâtiment BS) Station 4 CH - 1015 LAUSANNE DII - Exploitation Téléphone : +4121 693 52 22 Fax : +4121 693 52 00 Site web : www.epfl.ch/dii/



TO ALL USERS AT THE EPFL

Operating department information

Safety


Your safety against electrifying is insured by a complementary protection system (FI or DDR), installed on the boards of type R1, R2, R3, R4 and R5 at the EPFL. These switches equip specific premises, such as laboratories, repair shops, show rooms, testing benches, etc.


In accordance with the current norms, we invite you, as users whose activities are inherent in those kinds of premises, to use only plugs equipped with complementary protection systems (FI or DDR) for connecting electrical research and test devices.

These same norms impose periodical controls on us. However, as these equipments have a "test" button which makes it possible to verify their good working order, we advise you to carry out this check regularly (once a month). In case of defect, please call the internal number **115**.

Attention: The test interrupts power supply of the plugs groups protected by this system.

The 2 main models (FI or DDR) are:





Pictures showing above-mentioned boards which could be installed within the premises at the EPFL:









